

P S Y K R O M E T E R T A B E L L

för bestämning av relativa fuktigheten, då VENTILERAD psykrometer begagnas.

1. VÄRDEEN på vågta termometern.

		Skillnad mellan torra och våta termometerns temperatur																				
		2,5	3,0	3,5	4,0	4,5	5,0	5,5	6,0	6,5	7,0	7,5	8,0	8,5	9,0							
1,5	2,0															9,5	10	11	12	13	14	15
88	85	82	79	77	75	73	70	68	65	63	61	58	56	54	52	50	48	44	40	36	33	30
88	85	82	79	76	73	71	68	66	63	60	58	56	53	51	49	46	44	40	36	32	28	24
88	84	81	78	75	72	69	66	63	60	57	55	52	49	47	44	42	40	35	30	26	22	18
87	84	80	77	74	71	68	65	62	59	56	54	51	49	46	43	41	39	34	29	25	21	17
87	83	80	77	74	71	68	65	62	59	56	53	50	48	45	42	40	37	32	28	23	19	15
87	83	80	76	73	70	67	64	61	58	55	52	49	47	44	41	39	36	31	26	22	17	13
87	83	80	76	73	69	66	63	60	57	54	51	48	46	43	40	38	35	30	25	20	16	11
86	83	79	76	72	69	66	62	59	56	53	50	47	44	42	39	36	33	28	23	18	14	9
86	82	79	75	72	68	65	62	58	55	52	49	46	43	41	38	35	32	27	22	17	12	7
86	82	79	75	71	68	64	61	58	54	51	48	45	42	39	36	34	31	25	20	15	10	5
85	82	78	74	70	67	63	60	57	53	50	47	44	41	38	35	32	29	23	18	13	8	3
85	81	78	74	70	66	63	59	56	52	49	46	43	39	36	33	30	27	22	16	11	5	
85	81	77	73	69	65	62	58	55	51	48	44	41	38	35	32	28	25	20	14	8	3	
84	80	76	72	69	65	61	57	53	50	46	43	40	37	33	30	27	23	18	12	6		
84	80	76	72	68	64	60	56	52	49	45	42	38	35	31	28	25	21	15	9	4		
84	80	75	71	67	63	59	55	51	47	44	40	36	33	29	26	23	19	13	7	1		
83	79	75	70	66	62	58	54	50	46	42	39	35	31	27	24	21	17	10	4			
83	79	74	70	65	61	57	53	48	44	40	37	33	29	25	22	18	15	8	1			
83	78	73	69	64	60	56	52	47	42	38	35	31	27	23	20	16	12	5				
82	77	73	68	63	59	55	50	45	41	36	33	29	25	21	17	13	9	2				
82	77	72	67	62	57	53	48	44	39	35	31	26	22	18	14	10	6					
81	76	71	66	61	56	52	47	42	37	33	28	24	20	15	11	7	3					

